

RANGER DRAINAGE DISTRICT

DRIVEWAY & CULVERT INSTALLATION POLICY WITHIN THE DRAINAGE DISTRICT

CONCRETE PIPE - Estate Area

- ☐ Minimum of 32 feet of concrete pipe which includes 16 feet of straight pipe with an 8 foot mitered end on each side.
- ☐ Maximum of 48 feet of concrete pipe which includes 32 feet of straight pipe with an 8 foot mitered end on each side.
- ☐ Minimum of 10 feet between driveways.
- ☐ Maximum of 2 entry points to property from the roadway.
- ☐ Driveways must be located outside of any drainage easements and at least 6 feet from any property line.

PVC PIPE - City Area

- ☐ Minimum of 24 feet of PVC pipe which is approximately 20 feet of straight pipe and 2 foot on each side mitered.
- ☐ Maximum of 34 feet of PVC pipe which is approximately 30 feet of straight pipe and 2 foot on each side mitered.
- ☐ Minimum of 10 feet between driveways.
- ☐ Maximum of 2 entry points to property from the roadway.
- ☐ Driveways must be located outside of any drainage easements and at least 6 feet from any property line.

NOTES:

1. Variances from this Policy require application and approval from the District Board of Supervisors and is subject to engineering review.

2. A temporary construction access pipe and driveway is required if site work is to commence prior to the installation of a permanent driveway connection.



**WOHLFARTH CONSULTING
GROUP LLC**
ENGINEERS, PLANNERS

1315 South International Parkway Suite 1101
Lake Mary, Florida 32746
(407) 750-3123

**DRIVEWAY & CULVERT
INSTALLATION POLICY**

DATE: 12/4/25

**DRAWN
BY** BF

**CHECKED
BY** WEW